



“Empowerment through quality technical education”
AJEENKYA DY. PATIL SCHOOL OF ENGINEERING
Dr. D. Y. Patil Knowledge City, Charholi Bk., Via. Lohegaon,
Pune – 412 105.

*Department of Civil
Engineering*

*Water Test
&
Sewage Water Test
Report*



AJEENKYA D Y PATIL SCHOOL OF ENGINEERING

TESTING & CONSULTANCY SERVICES LAB

DR. D Y PATIL TECHNICAL CAMPUS CHARHOLI (BK.), PUNE - 412105

CONTACT: 7757888164, 9096288103, 8956897795

Test Report

Sample No: 100013

Report No.:16062024

Customer Name: ADYPSOE

Date of Sample collection : 14/06/2024

Customer Address: Lohegaon Pune

Date of Testing: 15/06/2024

Client Name: ADYPSOE

Report Date: 16/05/2024

Site: Outlet STP Plant

Sample Condition: Acceptable

Sample Sewage water

Water Quality Test Test Results

Sr. No	Test Particulars	Test Result	Units	Test Method	Acceptable limit
		Sample No 1			
1	BOD	17.35	mg/lit	IS:10500-2012 & APHA	Maximum 20
2	COD	124.74	mg/lit	IS:10500-2012 & APHA	Maximum 250
3	TSS	17.55	mg/lit	IS:10500-2012 & APHA	Maximum 30

Note: 1) The test report and results relate to the particular specimen/sample/s of the material as delivered/received and tested in laboratory. 2) Any test report shall not be reproduced except in full, without the written permission from DYPTCSC.

Tested by: Mrs. Ragini Kelkar,

Checked By: Dr. R. C. Katdare

Authorized Signatory

Prof. S. M. Karodpati
(HoD Civil Engg. Dept.)



AJEENKYA D Y PATIL SCHOOL OF ENGINEERING

TESTING & CONSULTANCY SERVICES LAB

DR. D Y PATIL TECHNICAL CAMPUS CHARHOLI (BK.), PUNE - 412105

CONTACT: 7757888164, 9096288103, 8956897795

Test Report

Sample No: 100012

Report No.:10012024

Customer Name: ADYPSOE

Date of Sample collection : 07/01/2024

Customer Address: Lohegaon Pune

Date of Testing: 08/01/2024

Client Name: ADYPSOE

Report Date: 10/01/2024

Site: Outlet STP Plant

Sample Condition: Acceptable

Sample Sewage water

Water Quality Test Test Results

Sr. No	Test Particulars	Test Result	Units	Test Method	Acceptable limit
		Sample No 1			
1	BOD	18.22	mg/lit	IS:10500-2012 & APHA	Maximum 20
2	COD	124.74	mg/lit	IS:10500-2012 & APHA	Maximum 250
3	TSS	15.54	mg/lit	IS:10500-2012 & APHA	Maximum 30

Note: 1) The test report and results relate to the particular specimen/sample/s of the material as delivered/received and tested in laboratory. 2)Any test report shall not be reproduced except in full, without the written permission from DYPTCSC.

Tested by: Mrs. Ragini Kelkar,

Checked By: Dr. R. C. Katdare

Authorized Signatory

Prof. S. M. Karodpati
(HoD Civil Engg. Dept.)



Dr. D Y PATIL SCHOOL OF ENGINEERING

TESTING & CONSULTANCY SERVICES LAB

DR. D Y PATIL TECHNICAL CAMPUS CHARHOLI (BK.), PUNE - 412105

CONTACT: 7757888164, 9096288103, 8956897795

Test Report

Sample No: 100011

Report No.:22062023

Customer Name: ADYPSOE

Date of Sample collection : 20/06/2023

Customer Address: Lohegaon Pune

Date of Testing: 21/06/2023

Client Name: ADYPSOE

Report Date: 22/06/2023

Site: Outlet STP Plant

Sample Condition: Acceptable

Sample: Sewage water

Water Quality Test Test Results

Sr. No	Test Particulars	Test Result	Units	Test Method	Acceptable limit
		Sample No 1			
1	BOD	15.76	mg/lit	IS 3025 (Part 44): 1993 (Reaffirmed 2009)	Maximum 20
2	COD	181.24	mg/lit	IS 3025 (Part 58) :2006	Maximum 250
3	TSS	19.12	mg/lit	IS: 3025 (Part 17) - 1984 (Reaffirmed - 2012)	Maximum 30

Note: 1) The test report and results relate to the particular specimen/sample/s of the material as delivered/received and tested in laboratory. 2) Any test report shall not be reproduced except in full, without the written permission from DYPTCSC.

Tested by: Mrs. Ragini Kelkar,

Checked By: Dr. R. C. Katdare

Authorized Signatory

Prof. S. M. Karodpati
(HoD Civil Engg. Dept.)



Dr. D Y PATIL SCHOOL OF ENGINEERING

TESTING & CONSULTANCY SERVICES LAB

DR. D Y PATIL TECHNICAL CAMPUS CHARHOLI (BK.), PUNE - 412105

CONTACT: 7757888164, 9096288103, 8956897795

Test Report

Sample No: 100010

Report No.:22012023

Customer Name: ADYPSOE

Date of Sample collection : 20/01/2023

Customer Address: Lohegaon Pune

Date of Testing: 21/01/2023

Client Name: ADYPSOE

Report Date: 22/01/2023

Site: Outlet STP Plant

Sample Condition: Acceptable

Sample: Sewage water

Water Quality

Test

Test Results

Sr. No	Test Particulars	Test Result	Units	Test Method	Acceptable limit
		Sample No 1			
1	BOD	16.58	mg/lit	IS 3025 (Part 44): 1993 (Reaffirmed 2009)	Maximum 20
2	COD	173.78	mg/lit	IS 3025 (Part 58) :2006	Maximum 250
3	TSS	20.54	mg/lit	IS: 3025 (Part 17) - 1984 (Reaffirmed - 2012)	Maximum 30

Note: 1) The test report and results relate to the particular specimen/sample/s of the material as delivered/received and tested in laboratory. 2) Any test report shall not be reproduced except in full, without the written permission from DYPTCSC.

Tested by: Mrs. Ragini Kelkar,

Checked By: Dr. R. C. Katdare

Authorized Signatory

Prof. S. M. Karodpati
(HoD Civil Engg. Dept.)